

TG003: PCB SERIAL COMMUNICATIONS TECHNICAL GUIDE

1.	DISC	CLAIM	ER	.2
2.	INTR	ODUC	CTION	.2
	2.1.	Piez	coelectric Disc Pump	2
	2.2.	Driv	er communication	3
	2.3.	Eval	luation Kit Motherboard	4
	2.3.1	۱.	Using the Evaluation Kit virtual COM Port	6
	2.3.2	2.	Attaching the PCB to your computer	6
	2.3.3	3.	Opening the COM port	6
	2.4.	Unit	S	6
3.	UART	INTE	RFACE	.7
	3.1.	Ove	rview	
	3.1.1		Writing	8
	3.1.2	2.	Reading	8
	3.2.	Stre	am mode	9
	3.3.	Num	nber formatting1	0
4.	I2C II	NTERI	FACE (FOR SPM ONLY)1	0
	4.1.	Ove	rview1	0



Address	.11
Writing to register with the int16_t type	.11
Writing to register with the float type	12
Reading a register with the int16_t type	.13
Reading a register with the float type	.14
IMANDS	.15
Pump enable	.15
Power Limit	15
Stream mode	15
Measurements	.16
Control Mode	.17
Manual Mode Settings	18
PID Mode Settings	18
Bang Bang Mode Settings	20
Measurement Settings	21
Miscellaneous Settings	23
Default values	25
THER SUPPORT	.27
Code Snippet Library	27
Additional Support	28
ISION HISTORY	.28
	Writing to register with the int16_t type



1. DISCLAIMER

This resource is provided "as is" and without any warranty of any kind, and its use is at your own risk. The Lee Company does not warrant the performance or results that you may obtain by using this resource. The Lee Company makes no warranties regarding this resource, express or implied, including as to non-infringement, merchantability, or fitness for any particular purpose. To the maximum extent permitted by law The Lee Company disclaims liability for any loss or damage resulting from use of this resource, whether arising under contract, tort (including negligence), strict liability, or otherwise, and whether direct, consequential, indirect, or otherwise, even if The Lee Company has been advised of the possibility of such damages, or for any claim from any third party.

2. INTRODUCTION

2.1. Piezoelectric Disc Pumps

The Lee Company's piezoelectric disc pumps are silent, high-performance gas micropumps.

The disc pumps are designed to provide highly accurate, ultra-smooth pressure and airflow control of gases. Owing to its operating mechanism, the disc pumps can be controlled with unmatched precision, yet at the same time respond to full-scale set point changes in a matter of a few milliseconds. The compact form factor means it can be tightly integrated into products, increasing portability.





Figure 1. A piezoelectric disc pump

2.2.Driver communication

The Lee Company provides a range of PCB designs for driving the disc pumps. All designs share a common register-based control interface, which is accessed either via a UART or I2C protocol, depending on the driver. This Technical Guide provides details of the commands recognised by the drivers.




Figure 2. Piezoelectric disc pump drive systems and communication protocol support



2.3. Evaluation Kit Motherboard

Typically, customers' first use of the disc pumps is with The Lee Company's Piezoelectric Disc Pump Evaluation Kit. The Evaluation Kit contains a General Purpose driver mounted on a motherboard. The motherboard acts as a breakout board for much of the driver's functionality, as well as adding useful peripherals, such as a dial control and pressure sensor.

The motherboard allows UART communication between a host PC, and the driver, using a USB-to-UART converter, which appears on the PC as a virtual COM port. All communication between the PC and driver uses the register-based UART interface described herein.





Figure 3. Connecting the Evaluation Kit Motherboard to a host PC



2.3.1. Using the Evaluation Kit virtual COM Port

The Evaluation Kit motherboard implements a serial-over-USB interface, accessible via a USB mini-B receptacle.

2.3.2. Attaching the PCB to your computer

The PCB is attached to the host computer via a USB A to USB mini B lead. A suitable lead is supplied with the Evaluation Kit. Please note that similar leads supplied (e.g. with bicycle lights) for battery charging tend not to have the data lines connected and are therefore unsuitable.

Upon first connecting the PCB to your computer, the operating system software should install the necessary driver to create a virtual COM port. If this does not happen automatically, please download and install the appropriate device driver from the FTDI website:

https://www.ftdichip.com/FTDrivers.htm

Once the COM port is installed, make a note of the port number. In Windows this can be identified by looking in the "Ports" section of the "Device Manager" window. With the Ports section open, unplug the USB cable connecting your computer to the PCB and take note of which COM port disappears. Reconnect the USB cable once the port is identified.

2.3.3. Opening the COM port

The PCB's COM port runs at a baud rate of 115,200, 8 bits, no parity, and one stop bit.

Please refer to the documentation supplied with your chosen software development environment for details of how to open a serial port.

2.4.Units

The following units are used:



Quantity	Unit
Flow	mL/min
Voltage	V
Current	mA
Power	mW
Frequency	Hz
Pressure	For the evaluation kit and drive PCBs, the following pressure units can be selected in the Disc Pump Control App:

3. UART INTERFACE

3.1.0verview

PCB operation is controlled by a number of registers, which offer either "read" or "read/write" access. Commands take the form of a string of ASCII characters terminated with a new-line character. Commands are sent to the driver, following which the driver responds to acknowledge the command and, in the case



of a read request, returns the requested value. The UART operates at 3.3V for the Smart Pump Modules and General Purpose Driver. For the older Fast Response PCB (obsolete) the UART operates at 2.5V.


3.1.1. Writing

To write to a register, send the write command, which takes the form:

#W<REGISTER_NUMBER>,<VALUE>\n

(Note that the terminating n' represents the ascii new-line character, i.e., n' shows the byte 0x12 being sent, rather than the individual characters n' and n')

The PCB responds to "write" commands by echoing the command back. This response should be read and checked by the controlling software to confirm that the command has been received correctly. If the command causes an error, or is not received at all, the PCB does not respond.



Example 1. Example UART interaction, writing registers 1 and 2. Writing to register 3 fails, as this register is read only. Blue: Command sent Green: Driver response

3.1.2. Reading


To read from a register, first send the read register command, which takes the following form:



#R<REGISTER_NUMBER>\n

(Note that the terminating '\n' represents the ascii new-line character, i.e., '\n' shows the byte 0x12 being sent, rather than the individual characters '\' and 'n')

The driver then responds by echoing the command back, followed by a comma and the register value.



Example UART interaction, reading registers 1, 2, and 3 in turn

Blue: Command sent Green: Driver response

3.2.Stream mode

When communicating over UART a streaming mode is available, in which a comma separate list of useful variables is sent periodically (at approximately 60Hz). This mode can be activated with register 2. Streamed variables take the form:

#S<PUMP_ENABLED>,<VOLTAGE>,<CURRENT>,<FREQUENCY>,<ANA1>,<ANA2>,<ANA3>,<FLOW>,<CHK>\n

Streaming format for drivers

#S<PUMP_ENABLED>,<VOLTAGE>,<CURRENT>,<FREQUENCY>,0,<DIGITAL_PRESSURE>,<ANA3>,0,<CHK>\n

Streaming format for modules



The <CHK> field contains a simple 1-byte checksum, used to validate the rest of the streamed message. The checksum is computed by taking the ascii value of each character in the line, before <CHK> appears, and adding them together. This sum is then limited to 0-255 by taking the modulo of the sum to 255:

SUM % 256 = expected checksum value

The normal command-response protocol can still be used with streaming mode activated. The driver will intersperse responses to read and write commands with the streaming output as necessary.

3.3.Number formatting

Numerical data is encoded in ASCII format. Floating point numbers should use the format *12.345*. Other number formats (e.g. scientific notation) are not supported.

4. I2C INTERFACE (FOR SPM ONLY)


4.1.0verview

The I2C bus is a synchronous, serial, 2-wire, half-duplex, multi-drop protocol that allows communication with several devices using a shared electrical bus.

Specification	Min	Typical	Max	Unit
I2C bus speed	100	100	400	kHz
Output level low			0.9	V
Output level high	2.4			V
Pull-up resistance on SDA & SCL	0.2		10	kOhm

Table 1. I2C Speed and Level Parameters for Ventus Drivers / Modules





Individual bytes are sent over the bus with the most significant bit first

Driver registers have two types:

int16_t A signed, 16-bit integer

float A 32-bit floating point value (typical IEEE 754 format)

When reading or writing to a register over I2C, the format of the register must be known up front, and the correct number of bytes read / written.

Note: The I2C Master must support clock stretching.

4.2.Address

The default device address is 37.

4.3.Writing to register with the int16_t type

To write to an int16_t register, the master:

- Initiates a write transfer with the driver, by sending the driver's I2C address, followed by the read/write flag, which is set to zero

Master to driver	
Driver to master	
Start Condition	S
Stop Condition	Ρ
Acknowledge	А
Not Aknowledge	Ν



- Sends a further byte to the driver, where the 7 LSBits (Least Significant Bits) indicate the register ID to be written, and the MSBit (Most Significant Bit) indicates a register write (set to zero)
- Sends the int16_t value as two bytes, with the least significant byte first

S	Address <6:0>	0	А	0	Register ID <6:0>	А	New Value <7:0>	А	New Value <15:8>	A P
	7-bit (MSBit first)				7-bit (MSBit first)		LSByte of int16_t, sent MSBit first		MSByte of int16_t, sent MSBit first]



4.4.Writing to register with the float type

To write to a float register, the master:

- Initiates a write transfer with the driver, by sending the driver's I2C address, followed by the read/write flag, which is set to zero
- Sends a further byte to the driver, where the 7 LSBits indicate the register ID to be written, and the MSBit indicates a register write (set to zero)
- Sends the float value as four bytes, with the least significant byte first

Address <6:0>	0	А	0	Register ID <6:0>	А	New Value <7:0>	А	New Value <15:8>
7-bit (MSBit first)			ļ	7-bit (MSBit first)		LSByte of float, sent MSBit first		2nd to LSByte of float, sent MSBit first
New Value <23:16>		А		New Value <31:24>	A	Ρ		
3rd to LsByte of float, se MSBit first	ent		MS	SByte of float, sent MSBit first				

Writing to a float Register



4.5.Reading a register with the int16_t type

To read to a register with the int16_t type, the master first:

- Initiates a write transfer with the driver, by sending the driver's I2C address, followed by the read/write flag, which is set to zero
- Sends a further byte to the driver, where the 7 LSBits indicate the register ID to be written, and the MSBit indicates a register read (set to one)

S	Address <6:0>	0	А	1	Register ID <6:0>	А	Ρ
_		1				1	
	7-bit (MSBit first)				7-bit (MSBit first)		



Second, the master:

- Initiates a read transfer with the driver, by sending the driver's I2C address, followed by the read/write flag, which is set to one
- Reads two bytes back from the driver, where the first byte is the least significant byte of the int16_t

S	Address <6:0>	1	А	Register Value <7:0>	А	Register Value <15:8>	Ν	Ρ
	7-bit (MSBit first)			LSByte of int16_t, sent		MSByte of int16_t, sent		
	7-DIL (IVISBIL IIISL)			MSBit first		MSBit first		
			l				1	

Master reads back the two bytes from the selected int16_t register

Master to driver	
Driver to master	
Start Condition	S
Stop Condition	Ρ
Acknowledge	А
Not Aknowledge	Ν



4.6.Reading a register with the float type

To read to a register with the float type, the master first:


- Initiates a write transfer with the driver, by sending the driver's I2C address, followed by the read/write flag, which is set to zero
- Sends a further byte to the driver, where the 7 LSBits indicate the register ID to be written, and the MSBit indicates a register read (set to one)

S	Address <6:0>	0	Α	1	Register ID <6:0>	А	Ρ
	7-bit (MSBit first)				7-bit (MSBit first)		

Master selects a register to read

Second, the master:

- Initiates a read transfer with the driver, by sending the driver's I2C address, followed by the read/write flag, which is set to one
- Reads four bytes back from the driver, where the bytes go least to most significant



Master reads back the four bytes from the selected float register



5. COMMANDS

5.1.Pump enable

This register controls whether the pump is enabled or not and overrides all other register settings.

ID	R/W	Name	Values	Туре
0	R/W	Pump enabled	0 = disabled 1 = enabled	int16_t

Example:

#W0,1\n Enables the pump

5.2. Power Limit

The maximum power to the pump under any circumstance is limited with this register value, which overrides all the control modes.

ID	R/W	Name	Values	Туре
1	R/W	Power limit	0 to 1400 milliwatts	int16_t

Example:

#W1,1000\n Limits the pump input power to 1000mW

5.3.Stream mode

Enables/disables the streaming mode.



ID	R/W	Name	Values	Туре
2	R/W	Enable stream mode	0 = disabled 1 = enabled	int16_t

Example:

#W2,1\n Enables the streaming mode

5.4.Measurements

Several read only registers for measurements are provided.

ID	R/W	Name	Values	Туре
3	R	Drive Voltage	0 to 60 volts	float
4	R	Drive Current	0 to 150 milliamps	float
5	R	Drive Power	0 to 2000 milliwatts	float
6	R	Drive Frequency	20000 to 23000 Hertz	int16_t
7	R	Analog 1 (dial on eval kit)	Value range dependent on channel gain and offset	float
8	R	Analog 2 (pressure on eval kit)	Value range dependent on channel gain and offset	float
9	R	Analog 3 (analog in on eval kit)	Value range dependent on channel gain and offset	float
32	R	Flow (optional eval kit flow sensor)	mL/min - range dependent on the connected sensor.	float



39	R	Digital Pressure Sensor (for the Smart Pump Module)	mBar	float
41	R	Reserved for future use	Reserved for future use	float

Example:

#R3\n	Requests the current drive voltage
#R3,25.123\n	Response from the PCB, for a drive voltage of 25.123 volts

5.5.Control Mode

The PCB offers three control modes:

- Manual mode, where the drive power can be set directly.
- PID mode, where the output of a PID controller sets the pumps driving voltage. Can be used for closed loop control of a parameter, such as pressure.
- Bang Bang mode, where a measured value (e.g. pressure) is controlled between two limits by enabling/disabling the pump (sometimes called 'hysteresis control').

ID	R/W	Name	Values	Туре
			0 = Manual	
10	R/W	Control mode	1 = PID	int16_t
			2 = Bang Bang	

Example:

#W10,1\n Set the PCB to use the PID control mode



5.6.Manual Mode Settings

One of four system inputs can be used to set the target drive power for the pump, in milliwatts.

ID	R/W	Name	Values	Туре
11	R/W	Manual mode source	The source of the target power (in milliwatts) when in manual mode: 0 = Set val (register 23) 1 = Analog 1 ⁺ (dial on evak kit) 2 = Analog 2 ⁺ (pr. sense on eval kit) 3 = Analog 3 (main analog input)	int16_t
11	R/W	Manual mode source	$1 = \text{Analog } 1^{\dagger}$ (dial on evak kit)	int16_t

[†]Not available with Smart Pump Module

Example:

#W11,2\n Use the Analog 2 value (after gain and offset) as the target power

5.7.PID Mode Settings

Several registers are available to configure the PID controller. The PID controller controls the power used to drive the pump in milliwatts.

Example: pressure target is 200mBar and the actual target is 150mBar. If the proportional coefficient is 10, the output pump power would be (200-150) * 10 = 500mW and similarly for the other coefficients.



ID	R/W	Name	Values	Туре
12	R/W	PID setpoint source	0 = Set val (register 23)1 = Analog 1 ⁺ (dial on evak kit)2 = Analog 2 ⁺ (pr. sense on eval kit)3 = Analog 3 (main analog input)	int16_t
13	R/W	PID input source	 0 = Set val (register 23) 1 = Analog 1⁺ (dial on evak kit) 2 = Analog 2⁺ (pr. sense on eval kit) 3 = Analog 3 (main analog input) 4 = External Flow Sensor* 5 = Digital pressure Sensor** 	int16_t
14	R/W	PID proportional coeff.	Unbounded. Values within -2000 to 2000 are recommended	float
15	R/W	PID integral coeff.	Unbounded. Values within -100 to 100 are recommended	float
16	R/W	PID integral limit coeff.	The PID mode output controls the power used to drive the pump in milliwatts. Therefore, setting this value to the peak drive power the pump might use is recommended. Typically, this can be left at 1,400.	float
17	R/W	PID differential coeff.	Unbounded, but rarely useful in practise. Leaving this at 0 is recommended.	float
33	R/W	Reset PID on turn on	0 = No reset 1 = PID loop reset when pump enabled	int16_t



[†] Not available with Smart Pump Module

- * Evaluation Kit only
- ** Smart Pump Module only

Example:

#W12,0\n	Set the manual set value as the PID setpoint source
#W13,2\n	Use Analog 2 as the PID input source
#W14,100\n	Use a proportional coefficient of 100
#W15,10\n	Use an integral coefficient of 10

5.8.Bang Bang Mode Settings

Several registers are available to configure the Bang Bang controller.

ID	R/W	Name	Values	Туре
18	R/W	Bang Bang input source	 0 = Set val (register 23) 1 = Analog 1⁺ (dial on eval kit) 2 = Analog 2⁺ (pr. sense on eval kit) 3 = Analog 3 (main analog input) 4 = External Flow Sensor* 5 = Digital pressure Sensor** 	int16_t
19	R/W	Bang Bang lower threshold	Unbounded	float



20	R/W	Bang Bang upper threshold	Unbounded	float
21	R/W	Bang Bang lower power mW	The drive power in milliwatts when the lower threshold is reached: 0 to 1400 milliwatts	float
22	R/W	Bang Bang upper power mW	The drive power in milliwatts when the upper threshold is reached: 0 to 1400 milliwatts	float

[†] Not available with Smart Pump Module

* Evaluation Kit only

** Smart Pump Module only

Example:

#W18,2\n	Use analog 2 as the input to the bang bang controller
#W19,10\n	Set the lower threshold to 10
#W20,100\n	Set the upper threshold to 100
#W21,1000\n	Set the power at the lower threshold to 1 watt
#W22,0\n	Turn the pump off when the upper threshold is reached

5.9.Measurement Settings

Several registers are available to configure the system inputs. Each input can be routed to a control mode via the registers for that mode.



The three analog inputs provide a raw value between 0 and 1. A gain and offset is applied to each analog input, before the value is routed to the areas where it is used. For example, a gain of 500, and offset of 250, could be applied to analog 3, and then analog 3 used as the input to the manual mode. This would allow the analog 3 input to control the drive power between 250mW and 750mW.

ID	R/W	Name	Values	Туре
23	R/W	Set Value	Unbounded. This value can be used as the input for the different modes.	float
24	R/W	Analog 1 Offset	Offset applied to the analog 1 input after gain is applied. float -99,999 to 99,999	
25	R/W	Analog 1 Gain	Gain applied to the raw analog 1 input, which is between 0 and 1. -99,999 to 99,999	float
26	R/W	Analog 2 Offset	Offset applied to the analog 2 input after gain is applied. -99,999 to 99,999	float
27	R/W	Analog 2 Gain	Gain applied to the raw analog 2 input, which is between 0 and 1. -99,999 to 99,999	float
28	R/W	Analog 3 Offset	Offset applied to the analog 3 input after gain is applied. -99,999 to 99,999	float



29	R/W	Analog 3 Gain	Gain applied to the raw analog 3 input, which is between 0 and 1. -99,999 to 99,999	float
40	R/W	Digital Pressure Offset (for Smart Pump Module)	-100 to 100mBar	float

Example:

#W23,500\n	Set the "Set Value" to 500
#W28,250\n	Set the analog 3 offset to 250
#W29,500\n	Set the analog 3 gain to 500

5.10. Miscellaneous Settings

ID	R/W	Name	Values	Туре
30	R/W	Store current settings	Writing a 1 to this register, causes the current settings to be stored in flash. These are then retrieved when the board powers up. Allow about 1s for the settings to be stored before turning off the board. Reverts to 0 once settings are stored.	int16_t
31	R	Error Code	0 = No error 1 = Error: short circuit 2 = Error: over frequency	



			3 = Error: under frequency	
34	R/W	Use frequency tracking	0 = Tracking off 1 = Tracking on	int16_t
35	R/W	Manual drive frequency (when register 34 is set to 0)	20000 to 23000 Hz	int16_t
36	R	Major firmware version		int16_t
37	R	Firmware / Device type	 1 = Fast Response Driver (obsolete) 2 = General Purpose Driver (synonymous with Cost Optimised) 3 = Smart Pump Module 	int16_t
38	R	Minor firmware version		int16_t
42	R/W	I2C address *	0 to 127 Write a 1 to register 30 to store the new address. Takes effect after a power cycle.	int16_t
	commu			
43	R/W	I2C / UART communication select *	1849 = Autodetect I2C/ UART communication at start-up 1892 = UART only 1935 = I2C only	int16_t



		register 30 to store the tion mode. Takes effect after a
	power cycle.	

* Smart Pump Module only

** If you have accidentally set the wrong value to this register and are not able to communicate with the board, please contact you Lee Sales Engineer.

Example:

#W34,0\n Disable frequency tracking

#W35,21000\n Drive at 21kHz

5.11. Default values

ID	Name	General purpose board default value	Smart Pump Module default value
0	Pump enabled	1 = enabled	1 = enabled
1	Power limit	1000 milliwatts	1000 milliwatts
2	Enable stream mode	0 = disabled	0 = disabled
10	Control mode	0 = manual	0 = manual
11	Manual mode source	$1 = Analog 1^{\dagger}$ (dial on evaluation kit)	3 = Analog 3 (main analog input)



12	PID setpoint source	$1 = \text{Analog } 1^{\dagger}$ (dial on	3 = Analog 3 (main
12		evaluation kit)	analog input)
13	DID input source	$2 = \text{Analog } 2^{\dagger}$ (pressure	5 = Digital pressure
13	PID input source	sense on evaluation kit)	Sensor**
14	PID proportional coeff.	5	5
15	PID integral coeff.	10	10
16	PID integral limit coeff.	1400	1400
17	PID differential coeff.	0	0
33	Reset PID on turn on	1 = PID loop reset when	1 = PID loop reset when
33		pump enabled	pump enabled
18	Bang Bang input source	$2 = Analog 2^{\dagger}$ (pressure	5 = Digital pressure
		sense)	Sensor**
19	Bang Bang lower threshold	10	10
20	Bang Bang upper threshold	50	50
21	Bang Bang lower power mW	1000 milliwatts	1000 milliwatts
22	Bang Bang upper power mW	0 milliwatts	0 milliwatts
23	Set Value	250	250
24	Analog 1 Offset	0	N/A
25	Analog 1 Gain	1000	N/A
26	Analog 2 Offset	Dependent on factory calibration.	N/A



27	Analog 2 Gain	Dependent on factory calibration.	N/A
28	Analog 3 Offset	0	0
29	Analog 3 Gain	1000	1000
40	Digital Pressure Offset (for Smart Pump Module)	N/A	Dependent on factory calibration.
34	Use frequency tracking	1 = Tracking on	1 = Tracking on
42	I2C address **	N/A	37
43	I2C / UART communication select **	N/A	1849 = Autodetect I2C/ UART communication at start-up

[†]Not available with Smart Pump Module

** Smart Pump Module only

6. FURTHER SUPPORT

6.1.Code Snippet Library

The Lee Company code snippet library, hosted on GitHub (<u>https://github.com/The-lee-company</u>), provides serial communication and control examples in Python for common functions, including turning the pump on and off, setting drive power, closed loop control of pressure and reading back and plotting data. The code snippet library implements the aspects of the communication protocol set out in this Application Note and is intended to support customers after their initial evaluation of our pump technology, as they move on to developing prototypes and products.



6.2.Additional Support

The Lee Company website provides advice on:

- Getting Started
- Applications
- Development Process
- Downloads (including datasheets, application notes, case studies and 3D models)

The Lee Company is happy to discuss next steps beyond prototyping, including system design. If you would like to discuss this with us, or for any other additional support, please contact your Lee Sales Engineer.

7. REVISION HISTORY

Date	Revision	Change
June 2023	R230621	Rebranded – name changes & link updates.
30 th Jan 2023	r230130	Added details about register 43. This register is active from SPM Firmware version 5.6. Changed maximum I2C frequency from 120kHz to 400kHz and minimum frequency from 10 to 100kHz Added range of values for registers 21, 22, 24-29 and 40. Changed register 16 PID integral limit coeff. Description to reflect how the register is really implemented. Updated the description of register 41.
1 st Dec 2022	r221201	Change pull-up resistance on SDA & SCL from 50 to 10k0hms
19 th Aug 2022	r220819	SUM % 255 changed to SUM % 256



13 May 2022	r130522	Added note that the I2C master must support clock stretching.	
05 May 2022	r050522	Correct 5.1. Added details about register 42	
21 March 2022	r220321	Remove FR driver physical board	
04 March 2022	r220304	Updates to include I2C and UART protocols and Smart Pump Module.	
03 August 2021	r210803	Update to TN and new document format.	
23 April 2021	r210423	Add setting 4 to Register 13 and Code Snippet Library to Further Support.	
19 June 2020	r200619	Corrected typing errors.	
28 May 2020	r200528	Added <flow> to streamed values in 3.4.</flow>	
29 January 2020	r200129	Correct wrong USB receptable specification in 3.0.	
28 May 2019	r190528	Reissue as AN003.	
31 January 2019	r190131	Updated the documentation to match the new evaluation kit commands.	
28 September 2018	r180928	Initial revision.	